



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 9, 2007

Re: ~~Ross County~~
~~Country Woods Estates~~
~~Self-Monitoring Report Violations~~
Ohio EPA Permit No. 0PV00025*BD
Correspondence (PWW)

Mr. John Cook, Owner
Country Woods Estates MHP
2150 Stone Road
Chillicothe, Ohio 45601

Dear Mr. Cook:

We have received your self-monitoring report covering the month of June 2007 for the Country Woods Estates mobile home park. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	18.9	6/1/2007
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.0939	.31312	6/1/2007
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3.0	18.9	6/7/2007
001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.141	.31312	6/7/2007

*7 D Conc is equal to average weekly concentration limit.
7 D Qty is equal to average weekly loading limit.
30 D Conc is equal to average monthly concentration limit.
30 D Qty is equal to average monthly loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. Our records also show that the NPDES permit has not yet been transferred to you through the completion and submittal of the Transfer of Application form. Please complete the attached form and return with your response to the violations.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

A handwritten signature in cursive script that reads "Jake Greuey".

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Wayne Grigsby, Operator