



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 15, 2007

**Re: Ross County
Kenowa Village MHP
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PV00010*BD
Correspondence (PWW)**

Ms. Gayle Scott, Owner
555 Greenlawn Avenue
Columbus, Ohio 43223

Dear Ms. Scott:

We have received your self-monitoring report covering the months of July and August for the Kenowa Village mobile home park's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	31616	Fecal Coliform	30D Conc	1000	8000.	7/1/2007
001	50060	Chlorine, Total Residual	1D Conc	.019	.38	7/12/2007
001	31616	Fecal Coliform	7D Conc	2000	8000.	7/15/2007
August 2007:						
001	31616	Fecal Coliform	30D Conc	1000	5500.	8/1/2007
001	31616	Fecal Coliform	7D Conc	2000	5500.	8/8/2007
001	50060	Chlorine, Total Residual	1D Conc	.019	.07	8/9/2007

*1D Conc is equal to the maximum daily concentration limit.
7 D Conc is equal to average weekly concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111. Review of the August MOR also revealed that only one residual chlorine reading was taken; please explain why this frequency violation occurred.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

A handwritten signature in cursive script that reads "Jake Greuey".

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Andrew Griner, Operator, Winelco Inc.