



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

July 11, 2007

**Re:** Ross County  
Nipgen Campground  
Compliance Inspection  
Correspondence (PWW)

Reverend Mike Holbrook  
Churches of Christ in Christian Union  
P.O. Box 10  
Circleville, Ohio 43113

Dear Mr. Holbrook:

On July 3, 2007, I conducted a Compliance Evaluation Inspection (CEI) of the Nipgen Campground's wastewater treatment facility. The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES Permit Number OPR00071\*CD. You were present during my inspection of the two lagoons and the surface sand filters.

As a result of my inspection, the following observations were made.

1. The two facultative lagoons appeared in relatively good condition although the weeds along the shorelines should be mowed.
2. Inspection of the chlorine contact tank showed the chlorine contact chamber to be removed and no disinfection was taking place. The chlorine contact chamber shall be re-installed on the inlet pipe to the contact tank immediately and the feeder tubes provided with tablets.

At the time of my inspection, the facility appeared to be in substantial compliance with the terms and conditions of the NPDES permit. Enclosed is a copy of my detailed inspection report.

If you have any questions please call me at (740) 380-5416.

Sincerely,

Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

Enclosure

c: Brian Larrick, Operator

**NPDES  
Compliance Inspection Report**

**A. NATIONAL DATA SYSTEM CODING**

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPR00071*CD	OH0094579	July 3, 2007	C	S	1

**B. FACILITY DATA**

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Camp Nipgen 329 S.R. 772 Nipgen, Ohio	1:30 p.m.	February 1, 2007
	Exit Time	Permit Expiration Date
	1:50 p.m.	January 31, 2012

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Reverend Mike Holbrook, District Superintendent	(740) 412-1792
Name, Address and Title of Responsible Official	Phone Number
Reverend Mike Holbrook Churches in Christ in Christian Union P.O. Box 10 Circleville, Ohio 43113	

**C. AREAS EVALUATED DURING INSPECTION**

<u>S</u> Permit	-- Flow Measurement	-- Pretreatment
<u>S</u> Records/Reports	-- Laboratory	<u>S</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	-- Sludge Storage/Disposal	Other
<u>S</u> Collection System		


(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

**D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)**

See attached letter.

  
 \_\_\_\_\_  
 Jake Greuey, Inspector, Ohio EPA, Southeast District Office

7/10/07  
 \_\_\_\_\_  
 Date

  
 \_\_\_\_\_  
 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

7/11/07  
 \_\_\_\_\_  
 Date