

Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 5, 2011

Re: Ross County
Mays MHP
OPV00017*DD
WWTP Inspection
Correspondence (PWW)

Ms. Darlene Huff, Owner
Mays MHP
168 S. Bridge Street
Chillicothe, Ohio 45601

Dear Ms. Huff:

On July 15, 2011, I conducted an inspection of the Mays Mobile Home Park wastewater treatment plant (WWTP). The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES permit number OPV00017*DD.

The following observations led to the marginal rating for Operations and Maintenance:

1. The alarms for the dosing tanks were turned off.
2. The sand in the sand filters was not level.
3. There was a buildup of solids in the weirs.
4. The pumps for the sand filter were on "Hand" instead of "Auto. Were the pumps wired in backwards or is there a problem with the pumps or electrical system?
5. There did not appear to be any dechlorination tablets in the feeder.

Enclosed is a copy of my detailed inspection report. Please provide a written response to these comments within 30 days upon receipt describing how the above items will be addressed and please call me at (740) 380-5268 to discuss the operations of the plant.

Sincerely,



Jack Knapp
District Representative
Division of Surface Water

JK/dh

Enclosure: Inspection Report

Southeast District Office
2195 Front Street
Logan, OH 43138-8637

740 | 385 8501
740 | 385 6490 (fax)
www.epa.ohio.gov

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PV00017*DD	OH0120308	July 15, 2011	R	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Mays MHP 3168 South Bridge Street Chillicothe, Ohio 45601	11:10 a.m.	July 1, 2007
	Exit Time	Permit Expiration Date
	11:30 a.m.	June 30, 2012

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Name, Address and Title of Responsible Official	Phone Number
Darlene Huff, Owner	(740) 663-4422


C. AREAS EVALUATED DURING INSPECTION

- | | | |
|--|---|---|
| <input checked="" type="checkbox"/> Permit | <input checked="" type="checkbox"/> Flow Measurement | <input type="checkbox"/> Pretreatment |
| <input checked="" type="checkbox"/> Records/Reports | <input type="checkbox"/> Laboratory | <input type="checkbox"/> Compliance Schedules |
| <input type="checkbox"/> Operations & Maintenance | <input checked="" type="checkbox"/> Effluent/Receiving Waters | <input checked="" type="checkbox"/> Self-Monitoring Program |
| <input checked="" type="checkbox"/> Facility Site Review | <input checked="" type="checkbox"/> Sludge Storage/Disposal | <input type="checkbox"/> Other |
| <input type="checkbox"/> Collection System | | |

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)


Please see attached letter.



Jack Knapp, Inspector, Ohio EPA, Southeast District Office

7/28/11

Date



Jennifer M. Witte for
Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

8/11/11

Date