



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 15, 2010

Re: Ross County
Paint Creek State Park
Compliance Inspection
Correspondence (PWW)

Mr. John Buchannon, Park Manager
ODNR, Paint Creek State Park
14265 U.S. Route 50
Bainbridge, Ohio 45612

Dear Mr. Buchannon:

On July 9, 2010, I conducted a Compliance Evaluation Inspection (CEI) of the Paint Creek State Park, Taylor Road Campground's wastewater treatment plant. The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES Permit Number OPP00076*ED. Mr. Matthew Lewis, plant operator, was present during the inspection.

At the time of my inspection all treatment units were found to be on-line and well maintained. Inspection of the filter beds found both to be clean with no vegetative growth or accumulation of solids and the final effluent to be clear with no objectionable odors. According to plant operator, Mr. Lewis all three lift stations within the park are fully functional duplex units with proper alarm systems in place to give the collection system a satisfactory rating. Currently, all wastewater analysis is contracted out to a commercial lab and only daily operational and monitoring requirements are conducted by the plant operator.

Attached for your review is my detailed inspection report. If you have any questions, please call me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

Enclosure

c: Matthew Lewis, Operator

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPP00076*ED	OH0041025	July 9, 2010	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Paint Creek State Park Taylor Road Campground Bainbridge, Ohio	10:40 a.m.	March 1, 2009
	Exit Time	Permit Expiration Date
	11:15 a.m.	February 28, 2014

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Matthew Lewis, Treatment Plant Operator	937-365-1401
Name, Address and Title of Responsible Official	Phone Number
Mr. John Buchannon, Park Manager ODNR- Paint Creek State Park 14265 U.S. Route 50 Bainbridge, Ohio 45612	

C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>S</u> Laboratory	<u>N/A</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u> </u> Other
<u>S</u> Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)


D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

* Contract laboratory used and not evaluated.
See attached letter.



Jake Greaney, Inspector, Ohio EPA, Southeast District Office

7/19/10
Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

7/19/10
Date