



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 6, 2010

**Re:** Ross County  
Tar Hollow State Park  
Compliance Inspection  
Correspondence (PWW)

Mr. Marty Hall, Park Manager  
Tar Hollow State Park  
16396 Tar Hollow Road  
Laurelville, Ohio 43135

Dear Mr. Hall:

On July 27, 2010, I conducted a Compliance Evaluation Inspection (CEI) of the Tar Hollow State Park's wastewater treatment plant that serves the lodge and park office. The purpose of the inspection was to determine compliance with the terms and conditions of National Pollutant Discharge Elimination System (NPDES) Permit Number OPP00037\*CD.

Inspection of the wastewater treatment plant found all treatment units to be fully operational and well maintained. The use of the filter fabric material used to cover both sand filter beds was observed as an effective weed control mechanism as well as an easy means to clean the filter beds. Final effluent was observed clear with no objectionable odor at the time of my inspection.

At the time of my inspection, this facility was found to be in substantial compliance with their NPDES permit. Attached for your review is my detailed inspection report. If you have any questions regarding my inspection, please call me at (740) 380-5416.

Sincerely,

Jake Greuey  
District Site Representative  
Division of Surface Water

JJG/dh

Enclosure

c: Steve Young, Operator