



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

May 27, 2008

Re: Scioto County
Tanglewood Subdivision WWTP
Self-Monitoring Report Violations
NPDES Permit No. OPG00050*ED
Correspondence (PWW)

Scioto County Commissioners
602 7th Street
Room 104 Courthouse
Portsmouth, Ohio 45662

Dear Commissioners:

We have received your self-monitoring report covering the months of October 2007 through March 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Report Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
Oct 2007	001	00530	Total Suspended Solids	30D Conc	12.0	14.6666	10/1/2007
Oct 2007	001	00530	Total Suspended Solids	7D Conc	18.0	20.	10/8/2007
Nov 2007	001	00530	Total Suspended Solids	30D Conc	12.0	56.25	11/1/2007
Nov 2007	001	00530	Total Suspended Solids	30D Qty	2.3	2.83497	11/1/2007
Nov 2007	001	00530	Total Suspended Solids	7D Conc	18.0	22.	11/8/2007
Dec 2007	001	00530	Total Suspended Solids	30D Conc	12.0	19.3333	12/1/2007
Dec 2007	001	00530	Total Suspended Solids	7D Conc	18.0	23.	12/1/2007
Dec 2007	001	00530	Total Suspended Solids	30D Qty	2.3	4.32626	12/1/2007
Dec 2007	001	00530	Total Suspended Solids	7D Conc	18.0	29.	12/8/2007
Dec 2007	001	00530	Total Suspended Solids	7D Qty	3.4	10.8667	12/8/2007

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5447.

Sincerely,

A handwritten signature in black ink, appearing to read "Mike Yandrich", written over a horizontal line.

Mike Yandrich
District Representative
Division of Surface Water

MY/dh