



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

May 13, 2008

Ron Bunofsky  
Astro Shapes  
65 Main St.  
Struthers, OH 44471

**RE: ASTRO SHAPES, CEI - LQG, OHD 154 165 591, MAHONING COUNTY  
TANK ASSESSMENT/RETURN TO COMPLIANCE**

Dear Mr. Bunofsky:

Thank you for your e-mail response to Ohio EPA's February 7, 2008 partial return to compliance letter. Your e-mail was received on May 12, 2008. The documentation you submitted included:

1. A photograph showing the audible and visual indicator of a high-level alarm that has been installed on the tank.
2. A document showing the operator panel read-out and explains how the high level alarm logic works.

Ohio EPA has reviewed the documentation and determined that it is sufficient to abate the violation cited in Ohio EPA's June 18, 2001, and May 24, 2007 Notices of Violation:

3. **Evaluation of Wastes  
OAC 3745-52-11**

No response to this letter is required.

Failure to list specific deficiencies in this communication does not relieve Astro Shapes from the responsibility of complying with all applicable Ohio EPA laws and regulations. Please be advised that present or past instances of non-compliance can continue as subjects of pending or future enforcement actions.

Please feel free to contact me at (330) 963-1170 if you have any questions.

Sincerely,

Edward J. D'Amato  
Environmental Specialist  
Division of Hazardous Waste Management

EJD:ddw

cc: Natalie Oryshkewych, DHWM, NEDO  
ec: Frank Popotnik, DHWM, NEDO  
Robert Almquist, DHWM, NEDO  
Harry Sarvis, DHWM, CO