



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 15, 2011

Gregory Chapman
Service Manager
Power City International Trucks, Inc.
13960 Brookpark Rd.
Cleveland, OH 44135

RE: POWER CITY INTL. TRUCKS, OHD 032 248 007, CUYAHOGA COUNTY, RTC

Dear Mr. Chapman:

On February 3, 2011, I contacted you to discuss the corrective actions taken at your facility in response to Ohio EPA's November 12, 2010 Notice of Violation (NOV) letter.

The following is the status of the previously identified violation:

1. OAC rule 3745-279-22(B)(C)(1)(D), Used Oil Storage Requirements

- A. This violation was previously abated.
- B. Power City failed to store used oil in an above-ground storage tank which was not leaking. During our February 3, 2011 telephone call, you indicated that a loose fitting was found on the above-ground storage tank which caused the leak. In December 2010, the fitting was fixed thus eliminating the leak. Additionally, you previously provided documentation which indicated that Heritage Crystal Clean removed used oil from the collection trenches at the facility. **This violation has been adequately abated. No further response is necessary.**

Ohio EPA's failure to list specific deficiencies or violations in this letter does not relieve your facility from having to comply with all applicable regulations.

Should you have any questions, please contact me at (330) 963-1108.

Sincerely,

Frank A. Zingales
Environmental Specialist
Division of Hazardous Waste Management

FAZ:cl

ec: Harry Sarvis, DHWM, CO
Nyall McKenna, DHWM, NEDO
Natalie Oryshkewych, DHWM, NEDO

cc: Marlene Kinney, DHWM, NEDO