

**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korieski, Director

OH4648612 BLACKHAWK BAR AND GRILL PWS

23 12/09/10



NOTICE OF VIOLATION – ACTION REQUIRED

December 9, 2010

RE: Logan County
Blackhawk Bar And Grill PWS
Non-Community, Transient
PWS ID: OH4648612

Bill Billing
11543 SR 365
Lakeview, OH 43331

Subject: Failure to Sample Drinking Water for Total Coliforms as Required

Blackhawk Bar And Grill PWS is in violation of Ohio Administrative Code (OAC), Rule 3745-81-21 for failure to comply with the total coliform monitoring.

Monitoring Period:	October 2010
Required Coliform Monitoring:	1 routine per Month
Sample Results Submitted:	Zero

To ensure the safety of drinking water provided by your system monitoring for total coliforms is essential.

ACTION REQUIRED:

1. **Notify the people served by this water system** using one or more of the methods and the timing as required by OAC, Rule 3745-81-32 to reach all persons served.

Timing: As soon as practical, but no later than 30 days after learning of the violation:

- Posting in conspicuous location, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Mail or other direct delivery to each customer;
 - Newsletters or newspaper;
 - E-mail to employees or students;
 - Send to parents or guardians of children at schools or day care facilities;
 - Posted notices must remain in place as long as the violation or situation exists, but in no case less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with the Ohio EPA beforehand.
2. **Complete the enclosed Verification Form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - SWDO. Include a copy of each notice distributed, published or posted.

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov

Blackhawk Bar And Grill PWS
December 9, 2010
Page 2

If total coliform samples were collected as required, submit the results as soon as possible. The monitoring violation would be rescinded and a reporting violation given for late submittal of the results.

If you have any questions, please contact me at 937-285-6417 or Dave Secor at 937-285-6114.

Sincerely,



Mark J. Verbsky, R.S.
Environmental Specialist

MJV/kla

Enclosures: Tier 3 Public Notification
Public Notice Instructions & Verification Form

cc: Logan County Health Department
Information Management Section, DDAGW, CO