



State of Ohio Enviro



Souti

* 0 H 4 6 3 3 9 1 2 7 1 3 1 9 0 8 *

401 East Fifth Street
Dayton, Ohio 45402-2911TELE: (937)285-6357 FAX: (937)285-6249
www.epa.state.oh.usTed Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

NOTICE OF VIOLATION – ACTION REQUIRED
--

March 31, 2008

RE: Logan County
Odnr Indian Lake St Pk - Campground
Transient Non Community
PWS ID: OH4633912Odnr Indian Lake State Park
12774 St Rt 235 N
Lakeview, OH 43331**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During First Quarter of 2008 (Monthly)**

Odnr Indian Lake St Pk - Campground is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:

- Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served. The appropriate methods for your system are listed below under the **Transient Non Community** column.

Public Community	Transient or Non Transient Non Community
<ul style="list-style-type: none"> • Mail or other direct delivery to each customer • If necessary to reach all persons regularly served, use other notification methods also, such as newspaper publication, public posting or Internet posting 	<ul style="list-style-type: none"> • Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas; • Mail or other direct delivery to each customer • Send to parents or guardians of children at schools or day care facilities • E-mail, newsletters or newspaper
<p>Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.</p>	

- Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - Southwest District Office. Include a copy of each notice distributed, published or posted.

Odnr Indian Lake St Pk - Campground

March 31, 2008

Page 2

4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at 937-285-6417.

Sincerely,



Mark J. Verbsky, R.S.
Environmental Specialist

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

pc: Logan County Health Department
~~Southwest District Office Files~~
Information Management Section, DDAGW, CO

MJV/ph