



State of Ohio Env



Southwest District

401 East Fifth Street
Dayton, Ohio 45402-2911TELE: (937)285-6357 FAX: (937)285-6249
www.epa.state.oh.usTed Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korieski, Director**CERTIFIED MAIL**

December 10, 2007

**RE: TREE LINKS GC-CLUBHOUSE
TRANSIENT WATER SYSTEM
LOGAN COUNTY
PWS ID# OH4647412**TREE LINKS GC- CLUBHOUSE
3482 COUNTY RD 10
BELLEFONTAINE, OH 43311**Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE, MONTHLY & Failure to Monitor with four repeat samples)**

During November 2007, your public water system incurred **acute** and **monthly** violations of Rule 3745-81-14 of the Ohio Administrative Code (OAC) and a **monitoring** violation of Rule 3745-81-21 (B)(1) of the OAC.

Acute and monitoring violations occur when four (4) total coliform bacteria repeat samples are not collected as required.

A monthly violation occurs when more than one or greater than five percent of your samples within the month are total coliform-positive.

Actions required as a result of the above violation

Step 1	<p>Within 24 hours, consult with Ohio EPA and issue the attached public notice in accordance with Rule 3745-81-32 of the Ohio Administrative Code using the following methods to reach all persons served by the public water system:</p> <p>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p>The language in italics on the attached public notice is mandatory and must be included as written.</p>
Step 2	<p>Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.</p>

Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the Southwest District Office of the Ohio EPA.
Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.
Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result you must take at least five (5) total coliform samples in December 2007.

If you have any questions, please contact me at (937) 285-6417 or Dave Secor at (937) 285-6114.

Sincerely,



Mark J. Verbsky, R.S.
Environmental Specialist Division of Drinking and Ground Waters

cc: Toni Buchanan, DDAGW, CO
LOGAN County Health Department

MJV/mab

Enclosures

DRINKING WATER WARNING

Tests show coliform bacteria in TREE LINKS GC-CLUBHOUSE water

BOIL YOUR WATER BEFORE USING OR USE BOTTLED WATER

Sampling conducted for our water system showed total coliform bacteria were found in samples collected in **November 2007**. We were required to collect four repeat samples within 24 hours of notification of any total coliform positive result to determine if *E. coli* or fecal coliform bacteria were present. These bacteria can make you sick, and are a particular concern for people with weakened immune systems. We did not collect all of the required repeat samples, and therefore cannot be sure that the drinking water does not pose an acute risk to human health.

What should I do?

- **DO NOT DRINK THE WATER WITHOUT BOILING IT FIRST.** Bring all water to a boil, let it boil for at least one minute, and let it cool before using, **or use bottled water**. Boiled or bottled water should be used for drinking, making ice, brushing teeth, washing dishes, and food preparation until further notice. Boiling kills bacteria and other organisms in the water.
- *Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.*
- The symptoms above are not caused only by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice. People at increased risk should seek advice about drinking water from their health care providers.

What happened? What is being done?

Bacterial contamination can occur when increased run-off enters the drinking water source (for example, following heavy rains). It also can happen due to a break in the distribution system (pipes) or a failure in the water treatment process.

We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact _____ at _____ or _____
name of contact phone number mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

PWSID# OH4647412

Date Distributed:

Tier 1: Total Coliform (no repeats taken)

PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR TIER 1 VIOLATIONS

The owner or operator of a public water system with a Tier 1 violation or situation that may pose an acute risk to human health is required to notify the persons served by the public water system. Notice shall be issued as soon as practical but **no later than 24 hours** after the system learns of the violation. Public notice shall be repeated as established during consultation with Ohio EPA.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
<p>Use one or more of the following methods to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> 1. Public notice issued by appropriate broadcast media (such as radio and television) 2. Public notice issued by continuous posting in conspicuous places throughout the area served by the water system (required to remain posted for as long as the violation exists) 3. Public notice issued by hand delivery to persons served by the water system 4. Public notice issued by another delivery method approved in writing 	<p>Describe actual methods used to notify public of the violation:</p> <ol style="list-style-type: none"> 1A. Name of station(s) 1B. Date provided to station(s) 2A. Dates of posting 2B. Locations of posting 3A. Date of delivery 4A. Method 4B. Date
<p>Additional methods established in consultation with Ohio EPA</p>	<ol style="list-style-type: none"> A. Method(s) B. Date(s)

Please check if the public notice used was provided by Ohio EPA (other side of this form) or another acceptable notice was used:

- A public notice as shown on the other side of this sheet was issued without changes.
 A different public notice was issued. **INCLUDE A COPY OF THE PUBLIC NOTICE.**

Signature of Responsible Official Date

Printed Name and Title of Responsible Official

TREE LINKS GC-CLUBHOUSE
 NAME OF PUBLIC WATER SYSTEM

PWSID NUMBER: OH4647412
 COUNTY NAME: LOGAN

For OEPA use only

Date PN Received:

PN acceptable:

PN not acceptable:

VIOLATION TYPE: 21, 22 & 25
 MONITORING PERIOD November 2007

9825 5286
9825 9479 0000
OFFICIAL USE
H002

U.S. Postal Service™
CERTIFIED MAIL™ RECEIPT
(Domestic Mail Only; No Insurance Coverage)

For delivery information visit our website at www.usps.com

(void)

OFFICIAL USE

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$

Postmark
Here

1/20/07

Sent To

1 All Links GC
clubhouse

Street, Apt. No.,
or PO Box No.
City, State, ZIP+4

See Reverse for Instructions

Certified Mail Provides:

- A mailing receipt for your mailpiece
- A unique identification number
- A record of delivery kept by the Postal Service for two years

Important Reminders:

- Certified Mail may **ONLY** be combined with First-Class Mail® or Priority Mail®
 - **NO INSURANCE COVERAGE IS PROVIDED** with Certified Mail. For valuables, please consider Insured or Registered Mail.
 - For an additional fee, a *Return Receipt* may be requested to provide proof of delivery. To obtain *Return Receipt* service, please complete and attach a *Return Receipt* (PS Form 3811) to the article and add applicable postage to cover the fee. Endorse mailpiece "Return Receipt Requested". To receive a fee waiver for a duplicate return receipt, a USPS® postmark on your Certified Mail receipt is required.
 - For an additional fee, delivery may be restricted to the addressee or addressee's authorized agent. Advise the clerk or mark the mailpiece with the endorsement "Restricted Delivery".
 - If a postmark on the Certified Mail receipt is desired, please present the article at the post office for postmarking. If a postmark on the Certified Mail receipt is not needed, detach and affix label with postage and mail.
- IMPORTANT: Save this receipt and present it when making an inquiry. Internet access to delivery information is not available on mail addressed to APOs and FPOs.**

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

TREE LINKS GC CLUBHOUSE
 3482 COUNTY RD 10
 BELLEFONTAINE OH 43311

2. Article Number

(Transfer from service label)

7003 0500 0002 4411 0856

COMPLETE THIS SECTION ON DELIVERY

A. Signature

X *Steve Graham* Agent Addressee

B. Received by (Printed Name)

STEVE GRAHAM

C. Date of Delivery

JUN 22 2004

D. Is delivery address different from item 1? YesIf YES, enter delivery address below: No

3. Service Type

 Certified Mail Express Mail Registered Return Receipt for Merchandise Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee)

 Yes

UNITED STATES POSTAL SERVICE



First-Class Mail
Postage & Fees Paid
USPS
Permit No. G-10

• Sender: Please print your name, address, and ZIP+4 in this box •

OEPA SWDO
MARK VERBSKY DDAGW
401 EAST FIFTH STREET
DAYTON OH 45402-2911

RECEIVED
OHIO EPA

JAN 23 2008

SOUTHWEST-DISTRICT

