



State of Ohio Environ



\* 0 H 5 5 3 0 4 1 2 3 5 4 8 8 0 9 \*

Southwest District

401 East Fifth Street  
Dayton, Ohio 45402-2911TELE: (937)285-6357 FAX: (937)285-6249  
www.epa.state.oh.usTed Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

<b>NOTICE OF VIOLATION – ACTION REQUIRED</b>
--

October 09, 2008

RE: Miami County  
Brukner Nature Center  
Transient Non Community  
PWS ID: OH5530412Brukner Nature Center  
5995 Horseshoe Bend Rd.  
Troy, OH 45373**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)  
During Third Quarter of 2008 (Monthly)**

Brukner Nature Center is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

**ACTION REQUIRED:**


- Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served. The appropriate methods for your system are listed below under the **Transient Non Community** column.

Public Community	Transient or Non Transient Non Community
<ul style="list-style-type: none"> <li>• Mail or other direct delivery to each customer</li> <li>• If necessary to reach all persons regularly served, use other notification methods also, such as newspaper publication, public posting or Internet posting</li> </ul>	<ul style="list-style-type: none"> <li>• Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;</li> <li>• Mail or other direct delivery to each customer</li> <li>• Send to parents or guardians of children at schools or day care facilities</li> <li>• E-mail, newsletters or newspaper</li> </ul>
<p>Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.</p>	

3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - Southwest District Office. Include a copy of each notice distributed, published or posted.
4. **Monitor with at least five (5) routine samples** in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at 937-285-6417 or Dave Secor at 937-285-6114.

Sincerely,



Mark J. Verbsky, R.S.  
Environmental Specialist

Enclosures: Tier 2 Public Notification  
Public Notice Instructions and Verification Form

pc: Miami County Health Department  
Southwest District Office Files  
Information Management Section, DDAGW, CO

MV/mab

# DRINKING WATER NOTICE

## Tests show coliform bacteria in Brukner Nature Center water

We routinely monitor for the presence of drinking water contaminants. We took \_\_\_\_\_ [number] samples for coliform bacteria during \_\_\_\_\_ [month and year]. \_\_\_\_\_ [Number/percentage] of those samples showed the presence of coliform bacteria. No more than [1 sample per month/ 5 percent of our samples] may show the presence of coliform bacteria during a month.

### What should I do?

- *You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor. People with severely compromised immune systems, infants, and some elderly people may be at increased risk. These people should seek advice about drinking water from their health care providers.*
- *Total coliform bacteria are generally not harmful themselves. Usually, coliforms are a sign that there could be a problem with the system's treatment or distribution system.*
- *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems. Fecal coliform or E. coli, which are bacteria of greater concern, were not detected in the water.*

### What is being done?

We are still detecting coliform bacteria. We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact \_\_\_\_\_ at \_\_\_\_\_  
name of contact phone number  
or at \_\_\_\_\_  
mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

PWSID# OH5530412

Date Distributed:

## PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR NON COMMUNITY PUBLIC WATER SYSTEMS WITH TIER 2 VIOLATIONS

The owner or operator of a non community public water system with a Tier 2 violation or situation shall notify the persons served by the public water system as soon as practical but **no later than 30 days** after the system learns of the violation. Public notice shall be repeated every 3 months as long as the violation or situation persists.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
<p><b>Use one or more of the following methods to reach all persons served by the public water system:</b></p> <ol style="list-style-type: none"> <li>1. Public notice issued by posting in conspicuous locations throughout the distribution system (required to remain posted for as long as the violation exists, but in no case less than 7 days)</li> <li>2. Public notice issued by mail or other direct delivery to each customer and service connection (where known).</li> </ol>	<p><b>Describe actual methods used to notify public of the violation:</b></p> <p>1A. Dates of posting _____</p> <p>1B. Locations of posting _____ _____</p> <p>2. Date of mailing/delivery _____</p>
<p><b>Schools and Day-Care Facilities</b> must notify parents or guardians of children being served by methods besides posting, such as a newsletter, e-mail notice, or direct mailing</p>	<p>A. Method(s) _____ _____</p> <p>B. Date(s) _____</p>
<p><b>If the above methods do not reach all persons served</b>, also use any other method reasonably calculated to reach other persons served by the system (e.g. publication in a local newspaper or newsletter, use of e-mail to notify employees or students, or delivery of multiple copies to central locations).</p>	<p>A. Method(s) _____ _____</p> <p>B. Date(s) _____</p>

**Please check if the public notice used was provided by Ohio EPA (other side of this form) or another acceptable notice was used:**

\_\_\_\_\_ A public notice as shown on the other side of this sheet was issued without changes.

\_\_\_\_\_ A different public notice was issued. **INCLUDE A COPY OF THE PUBLIC NOTICE.**

\_\_\_\_\_  
Signature of Responsible Person                      Date

\_\_\_\_\_  
Printed Name and Title of Responsible Person

Brukner Nature Center  
 OH5530412  
 Miami County  
 Third Quarter of 2008  
 Total Coliform Monthly MCL (Vio. Type 22)

<b>For Ohio EPA use only:</b>	
Date PN received: _____	PN acceptable: _____ PN not acceptable: _____