



**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korfeski, Director

OH5551412 SAFE HARBOR MINISTRIES

22 08/31/10



NOTICE OF VIOLATION – ACTION REQUIRED

August 31, 2010

RE: Miami County
Safe Harbor Ministries
Non-Transient Non-Community
PWS ID: OH5551412

Shelly Young
2464 Peters Rd
Troy, OH 45373

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During Third Quarter of 2010 (Monthly)**

Safe Harbor Ministries is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful bacteria may be present.

ACTION REQUIRED:

1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
2. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Mail or other direct delivery to each customer;
 - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - SWDO. Include a copy of each notice distributed, published, or posted.

Safe Harbor Ministries

August 31, 2010

Page 2

4. Monitor with at least five (5) routine samples in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, please contact me at 937-285-6417 or Dave Secor at 937-285-6114.

Sincerely,



Mark J. Verbsky, R.S.
Environmental Specialist

MJV/kla

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Miami County Health Department
Information Management Section, DDAGW, CO