



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Putnam County  
Village of Leipsic  
NPDES Permit

June 22, 2011

Mr. Kevin Lammon  
Village Administrator  
Village of Leipsic  
Town Hall  
142 East Main Street  
Leipsic, Ohio 45856

Dear Mr. Lammon:

On June 13, 2011, I conducted an inspection at the Village of Leipsic's Wastewater Treatment Plant. Mr. Tony Shroeder and Mr. Russ Teders were present and provided information on the operation and maintenance of the plant. During our visit, all major treatment units were in operation. The discharge observed at the UV tank was clear with no noticeable odor.

A review of the discharge monitoring reports (DMRs) from November 2010 to June 2011 shows that there have been several effluent limit violations. The specific instances of non-compliance are enclosed on a separate sheet.

If you have any questions, please contact me at (419) 373-3053.

Sincerely,

Ryan Gierhart  
Division of Surface Water

/cs

Enclosure

pe:DSW;NWDO:File

Get New Data

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00040*OD	January 2011	001	00530	Total Suspended Solids	7D Conc	29.85	32.	1/22/2011
2PB00040*OD	March 2011	001	50092	Mercury, Total (Low Le	30D Qty	0.0000	.00018	3/1/2011
2PB00040*OD	May 2011	001	00552	Oil and Grease, Hexane	1D Conc	10	11.	5/3/2011