



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Richland County  
Blust Apartments  
NPDES Permit

December 2, 2009

Mr. James Blust  
2385 State Route 603  
P.O. Box 7111  
Ashland, Ohio 44805

Dear Mr. Blust:

On November 12, 2009, an inspection was made of the wastewater treatment facilities serving your apartment building located at 975 Dianewood Drive, Mansfield, Richland County. The inspection was made at your request in order to confirm the abandonment and demolition of the wastewater treatment plant and the connection of the sewage flow to the Richland County sanitary sewer system.

At the time of the inspection all work had been completed and the flow was being sent to the sanitary sewer system. The former treatment plant had been pumped out and the tanks had been demolished. The new sewer lateral appeared to have been constructed as approved in your Permit to Install application.

Please send a written letter to our office requesting termination of coverage of your NPDES permit and our office will then begin that process. Until the permit is terminated you are still responsible for submitting monthly reports.

If you have any questions please call me at 419-373-3070.

Sincerely,

Walter Ariss  
Environmental Specialist II  
Division of Surface Water

//lr

pc: [DSW-NWDO File]  
Richland County Health Department