



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Richland County  
Brown Derby Roadhouse  
NPDES Permit

August 13, 2008

Mr. Bill Tsavaris, General Manager  
Brown Derby Roadhouse  
3985 Park Avenue West  
Ontario, Ohio 44862

Dear Mr. Tsavaris:

On July 31, 2008, an inspection was made of the wastewater treatment facilities serving the Brown Derby Roadhouse located at 3985 Park Avenue West, Ontario, Richland County. At the time of the inspection no major concerns were noted. All major treatment units appeared to be functioning normally. The water in the aeration tanks had good roll and a healthy brown color. A clear final effluent was being discharged to the receiving stream.

It was observed that a significant amount of grease was floating in the second aeration tank. The level of grease in the grease trap should be checked and the tank pumped if necessary. The outlet baffle within the grease trap should be checked to make sure no floating grease is able to flow into the treatment plant.

A review of your discharge monitoring reports for the period of October 2007, through May 2008, revealed three limit violations for the parameters contained in your NPDES permit. These violations occurred in March 2008, for exceeding the ammonia limits. This treatment plant continues to meet the permit limits with regularity.

Please call me at 419-373-3070 if you have any questions.

Sincerely,

Walter Ariss  
Environmental Specialist II  
Division of Surface Water

/llr

Enclosure

pc: ~~DSW-NWDO File~~ ;  
Angelo Klousadis, City of Mansfield w/ enclosure  
Lonnie McGhee, McGhee's Technical Water Services Inc. w/ enclosure

OHIO ENVIRONMENTAL PROTECTION AGENCY

OPERATION AND MAINTENANCE INSPECTION  
WWTP'S LESS THAN 25,000 GPD

NPDES Permit No. 2 PR00049

Facility Name Brown Derby Roadhouse Expiration Date 3/31/2010  
Facility Address 3985 Park Ave West Date 7/3/08 Time 3:00 am KPM  
City Ontario County Richland Township \_\_\_\_\_  
Name and Address of Owner Bill Tsavaris

Person Contacted \_\_\_\_\_ Owner Phone \_\_\_\_\_

Flow: Design 5,000 GPD Present 3,000-4,000 GPD (metered - estimated)

Trib. Pop. \_\_\_\_\_ (actual - estimated) Weather at time of inspection: Temp 84° SUNNY

OEPA Personnel Walter Ariss District NWDO

1. Plant Effluent - Mark Severity No.

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None	<input checked="" type="checkbox"/>	Clear	<input checked="" type="checkbox"/>	None	<input checked="" type="checkbox"/>	Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

2. Effect of effluent on Receiving Stream Name: unnamed trib Clear Fork Mohican

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None	<input checked="" type="checkbox"/>	Clear	<input checked="" type="checkbox"/>	None	<input checked="" type="checkbox"/>	Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

3. a. Plant has \_\_\_\_\_ excellent  good \_\_\_\_\_ fair \_\_\_\_\_ poor operation  
 b. Plant has \_\_\_\_\_ excellent  good \_\_\_\_\_ fair \_\_\_\_\_ poor maintenance  
 c. Sand filters have \_\_\_\_\_ excellent \_\_\_\_\_ good \_\_\_\_\_ fair \_\_\_\_\_ poor maintenance  
no sand filters

d. Not operating at expected efficiency due to:

- (1) \_\_\_\_\_ hydraulic overload
- (2) \_\_\_\_\_ organic/ solids overload
- (3) \_\_\_\_\_ personnel inefficiency
- (4) \_\_\_\_\_ equipment failure
- (5) \_\_\_\_\_ wastes
- (6) \_\_\_\_\_

Disinfection: (Required May 1 thru Oct.31.)	
IN <input checked="" type="checkbox"/>	OUT _____
<input checked="" type="checkbox"/>	_____ Chlorination Tablets
_____	_____ Dechlorination Tablets
_____	_____ U.V.

Yes No

4.  \_\_\_\_\_ Compliance with NPDES Permit

Periodic Violations Y N Parameters: NH<sub>3</sub> in March '08

Chronic Violations \_\_\_\_\_

5.  \_\_\_\_\_ Adequate plant safety

6.  \_\_\_\_\_ Operation and Maintenance Service Name McGhee's TWSI

Frequency of Visits ?

Facility Name: Brown Derby

Process	# Units	Unit	If Needed - Description and Comments
Preliminary	<input checked="" type="checkbox"/>	Trash Trap	Pumping Frequency: ?
		Grease Trap	Pumping Frequency:
		Bar Screen	
		Comminutor	
		Flow Equalization	
Aeration Equipment	<input checked="" type="checkbox"/>	Plant Timer <u>Y</u> <input checked="" type="checkbox"/> <u>N</u>	Cycle Time:
		Motor/ Blower Unit <i>running</i>	
Secondary Treatment	<input checked="" type="checkbox"/>	Aeration Tank - <i>grease floating in 2nd aeration tank</i>	Color: <i>good color</i> Adequate Aeration: Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
Final Settling	<input checked="" type="checkbox"/>	Clarifier	
	<input checked="" type="checkbox"/>	Sludge Return	In <input checked="" type="checkbox"/> Out <input type="checkbox"/>
		Surface Skimmer	In <input type="checkbox"/> Out <input type="checkbox"/>
		Fixed Media Clarifier	
<del>Tertiary Treatment</del>		Surface Sand Filter	
		Polishing Pond	
		Other	
Disinfection	<input checked="" type="checkbox"/>	Chlorine Tube Feeder	
	<input checked="" type="checkbox"/>	Dechlorination Tube Feeder	
		Ultraviolet (UV)	
Flow Metering		Elapsed Pump Time	
		Recorder (continuous total)	
<del>Pumps</del>		Raw Wastewater (type)	
		Sand Filter Effluent Dosing	
<del>Sludge Handling</del>		Aerated Storage Tank	
		Sludge Drying Bed	
Sludge Disposal	<input checked="" type="checkbox"/>	Municipal POTW	
		Landfill	
		Land Application	
Advanced Treatment	<input checked="" type="checkbox"/>	Post Aeration	
		Spray Irrigation	
		Other	