



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Richland County
Columbia Gas-Weaver Compressor
Station
NPDES Permit

November 14, 2007

Tim Keslar
EH&S Coordinator
Columbia Gas, Weaver Compressor Station
2873 Pleasant Valley Road
Lucas, Ohio 44843

Dear Mr. Keslar,

On October 11, 2007, an inspection was made of the wastewater treatment facilities serving the Columbia Gas Weaver Compressor Station, located at 2873 Pleasant Valley Road, Lucas, Richland County. The inspection included a short discussion and a tour of the facilities. No major concerns were noted.

Wastewater is generated from groundwater seepage into the basement of the compressor buildings and from washdown flows associated with cleaning the compressors. These flows are collected in a sump and pumped to a carbon filtration unit which provides treatment to the wastewater.

A review of your monthly reports from September 2004 through September 2007 revealed two violations of the limits in your NPDES permit. One violation was for PCB 1242 and the other for pH.

If you have any questions please feel free to give me a call at 419-373-3070.

Sincerely,

Walter Ariss
Environmental Specialist II
Division of Surface Water

/lb

~~pc: NWDO-DSW-file~~