



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Richland County
Jefferson Township-Bellville Fire Station
Construction
Storm Water

September 27, 2011

Ms. May Jean Hickerson
Jefferson Township-Bellville Fire Department
470 South Main Street
Bellville, Ohio 44813

Mr. Ralph Robinson
Terra Valley Excavating
P.O. Box 325
Bellville, Ohio 44813

Dear Ms. Hickerson and Mr. Robinson:

On June 23, 2011, Ohio EPA representative Brian McGlown inspected the Jefferson Township-Bellville Fire Station at 460 South Main Street, Jefferson Township. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity; Facility ID No. 2GC00726*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

It appears that the project at 460 South Main Street is complete. It also appears that storm sewers drain into a detention pond to meet the post-construction storm water management requirement. A Notice of Termination (NOT) **must be filed** to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

1. Final stabilization has been established on all areas of the site for which the permittees are responsible. Final stabilization means that all soil-disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized.
2. Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.


Ms. May Jean Hickerson
Mr. Ralph Robinson
September 27, 2011
Page Two

Your site appears to meet the above conditions. If this is accurate and you have installed the required post-construction storm water management facilities, please file the NOT form. The NOT form and instructions can be found on our website:
<http://www.epa.ohio.gov/dsw/storm/stormform.aspx>.

NOTs must be mailed to Ohio EPA's Central Office in Columbus, Ohio within 45 days of when the above criteria are met.

If there are any questions, please contact me at (419) 373-3009.

Sincerely,

A handwritten signature in cursive script, appearing to read "Lynette Hablitzel".

Lynette Hablitzel, PE
Division of Surface Water
Storm Water Program

/cs

pc: DSW, NWDO File