



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Notice of Violation
Auglaize County
Cridersville WWTP
Ohio EPA Permit No. 2PB00048
NPDES Permit No. OH0020222

September 27, 2011

Mr. John J. McDonald
Village Administrator
Village of Cridersville
110 West Main Street
Cridersville, Ohio 45806

Dear Mr. McDonald:

We are in receipt of your self-monitoring report covering the months of April through June 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of non-compliance are attached on a separate sheet.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373 – 3022.

Sincerely,

Justin A. Williams
Division of Surface Water

/cs

Enclosure

pc w/Enclosure: NWDO – DSW File

Get New Data

Violations for Cridersville LUWP - April - June 2011

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00048*HD	June 2011	001	50092	Mercury, Total (Low Le	30D Conc	1.3	1.79	6/1/2011
2PB00048*HD	April 2011	001	00530	Total Suspended Solids	30D Qty	36	39.2601	4/1/2011
2PB00048*HD	April 2011	001	00530	Total Suspended Solids	7D Qty	55	57.6436	4/1/2011