Ohio | Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Notice of Violation
Van Wert County
Convoy WWTP
Ohio EPA Permit No. 2PB00005
NPDES Permit No. OH0023493

September 23, 2011

Mr. Terry Crowle
WWTP Superintendent
Village of Convoy
P.O. Box 310
Convoy, Ohio 45832

Dear Mr. Crowle:

We are in receipt of your self-monitoring report covering the months of April through June 2011 for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of noncompliance is attached on a separate sheet.

We have received your email dated May 26, 2011, regarding the referenced violation and require no further information at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's *"Facility Pollution Prevention Guide"* (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, feel free to contact me at (419) 373 – 3022.

Sincerely,

Justin A. Williams

Justin A. Williams
Division of Surface Water

/cs
Enclosure
pc w/Enclosure: NWDO - DSW File

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov

Get New Data

Violations for Conway WWTP - April - June 2011

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00005*JD	May 2011	001	00530	Total Suspended Solids	7D Qty	14.0	15.6805	5/22/2011