



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 13, 2009

Vicki Lewis
Ohio Health
561 West Central Avenue
Delaware, OH 43015

**Re: Storm Water Inspection at Delaware Health Village Phase 1
Permit #4GC02678*AG**

Dear Ms. Lewis:

This letter is written in follow-up to a construction storm water inspection by Heather Nichols and Amber Miller, of the Ohio EPA, at Delaware Health Village Phase 1 located East of Glenn Parkway between Peachblow and Cheshire Road on June 25, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- Upon inspection, current silt fence and all sediment controls have failed along the northwest corner of the site and will require repair (See Figure 1 & 2).
- This has resulted into sediment run-off directly into a stream and extreme erosion to the barren areas noted in Figures 3, 4 & 5.
- The sediment pond is functioning as intended. However, please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

21 Day Rule:

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days (See Figure 6).
- Sediment and erosion controls must remain until at vegetation is well established.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Vicki Lewis
Ohio Health
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Belaware Health Village Phase 1 June 25, 2009



Figure 1: Silt Fence needs repair



Figure 2: Silt Fence needs repair






Figure 3: Sediment leading into stream

Delaware Health Village Phase 1
Olenlangy River Watershed
Photo by: Heather Nichols
June 25, 2009




Figure 4: Sediment leading into stream







Figure 5: Sediment in stream



Figure 6: Barren Areas requiring at least 70% Vegetation





4GC0276920090710