



State of Ohio Environmental Protection Agency

Central District Office

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

February 24, 2009

Ted Hunker
Tartan Management
555 Metro Place North, Suite 645
Dublin, OH 43017**Re: Construction Storm Water Inspection at Bedford Landfill**

Dear Mr. Hunker:

This letter is written regarding the storm water inspection that I conducted at Bedford Landfill, located in Gahanna in Franklin County, on February 11, 2009. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

- Please continue with stabilization of the site. Significant portions of the site have been stabilized. Specifically the area where the pre-existing shale piles were stored will require additional protections.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Bedford Landfill 02-09-09

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director





State of Ohio Environmental Protection Agency

Central District Office

RECEIPT ADDRESS:

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

February 24, 2009

Jeff Sheets
Teays Valley Local School District
385 Circleville Avenue
Ashville, OH 43103

**Re: Notice of Violation
Commercial Point Middle School / Pickaway County**

Dear Mr. Sheets:

This letter is written regarding the storm water inspection I conducted on February 19, 2009, of the construction activities at Commercial Point Middle School located along Scioto Darby Road. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following was observed or discussed at the site:

Sediment and Erosion Controls:

There was a turbid discharge being pumped from the sediment pond located along S.R. 762. There shall be no turbid discharges to waters of the state. It appears that a new filter bag possibly several, need to be installed at the end of the pump discharge. Also, the suction side of the pump should not be placed directly on the bottom of the sediment pond. Please see attached pictures.

Please insure that mud is not being tracked off-site. It appeared that a small amount of mud was being tracked on to Scioto Darby Road. Please utilize controls to prevent mud from being tracked off-site.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.


Sincerely,


Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office


Enclosure


c: Jeff Bohne, Water Quality Supervisor, DSW/CDO
Rick McKnight, Ruscilli Construction Company

GLS/nsm Commercial Point Middle School, February 19, 2009
Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director










Commercial Point Middle School
Scioto River Watershed
February 19, 2009
Photo by: Greg Sanders



Commercial Point Middle School
Scioto River Watershed
February 19, 2009
Photo by: Greg Sanders

