



State of Ohio Environmental Protection Agency

Central District Office

MAILING ADDRESS:

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 14, 2003

Marcel Van Der Burg
Van Der Burg Dairy LLC
431 South Water Street
Williamsport, OH 43164

Re: Construction Storm Water Inspection at Van Der Burg Dairy LLC

Dear Mr. Van Der Burg:

This letter is written regarding the storm water inspection that Darrick Tibyash and Adam Knoll, of Ohio EPA, conducted at Van Der Burg Dairy LLC, located at 13995 Blain Road Mount Sterling, OH 43413 in Pickaway County, on July 7, 2008. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

- Upon inspection it appeared that this site has been abandoned for some time. The lack of activity and inadequate vegetative cover is resulting in significant erosion throughout the entire site (See Photo Figure 1 and 2). This erosion is causing excess sediment to be deposited in the pond (See Photo Figure 3).
- The detention basin noted onsite must be modified to address sediment control via the installation of a temporary riser. This will allow for additional settling time for the suspended solids to settle prior to a final discharge from the site (See Photo Figure 4).
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven days (See Photo Figure 5).

Post Construction Requirements:

The General Permit mandates specific water quality treatment for storm water following the completion of construction (see attachment). Please be able to demonstrate that your post construction requirements per the General Permit will be met. Please submit to my attention, the water quality calculations demonstrating compliance. This information can be sent to my attention via a response letter, or to my email at harry.kallipolitis@epa.state.oh.us.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Marcel Van Der Burg
Van Der Burg Dairy LLC
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,




Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

Enclosure


c: Jeff Bohne, Water Quality Supervisor, DSW/CDO
Cathy Alexander, Water Quality Engineer 2, DSW/CO

HK/nsm Van Der Burg Dairy LLC 7-7-08



VAN DER BURG DAIRY LLC
Pickaway County
Deer Creek Watershed
Photo by: Darrick Tihyash and Adam Knapp
July 7, 2008
Note: Site appears vegetated but vegetation is inadequate

Figure 1 Inadequate vegetative cover



VAN DER BURG DAIRY LLC
Pickaway County
Deer Creek Watershed
Photo by: Darrick Tihyash and Adam Knapp
July 7, 2008

Note: Major erosion leading to pond

Figure 2 Major erosion noted

1234

