



State of Ohio Environmental Protection Agency

STREET ADDRESS

Central District Office

MAILING ADDRESS

Lazarus Government Center
122 S. Front Street
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, Ohio 43216-1049

December 22, 2006

RE: Meadowmoore, Sec. 3, Ph. 1-4

Donley, Inc.
John Donley
7600 Farmsbury Dr.
Reynoldsburg, OH 43068

Dear Mr. Donley:

This letter is written regarding the storm water inspection that I conducted at Meadowmoore, Sec. 3, Ph. 1-4, located in Fairfield County, on December 19, 2006. I understand that these construction activities are covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

1. Overall, the site appeared in compliance with the General Storm Water Permit. However, one section of silt fence was failing and was allowing sediment to discharge to Meadowmoore Boulevard and into a storm culvert. Please have the section of silt fence near Meadowmoore Boulevard repaired and maintained.
2. Be aware that the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven (7) days of the last earth disturbing activity. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. This applies to any large barren areas and dirt stockpiles around the site. Please see attached photo.
3. Winter Rule: Considerations must be made at this time to ensure all barren areas are protected from erosion in preparation for the upcoming winter months. Please note, in the event that earthmoving activities extend beyond the effective growing season, alternative erosion protection will be required to fully stabilize the site for winter. (i.e., erosion control matting or crimp mulching).

Bob Taft, Governor
Bruce Johnson, Lieutenant Governor
Joseph P. Koncelik, Director

Donley, Inc.
John Donley
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851. A follow up inspection will be conducted in approximately two weeks to ensure that the minimum conditions of the General Permit have been met.

Sincerely,



Gregory L. Sanders
Stormwater Unit
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO