



State of Ohio Environmental Protection Agency

STREET ADDRESS

Lazarus Government Center  
122 S. Front Street  
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS

P.O. Box 1049  
Columbus, Ohio 43216-1049

December 18, 2006

Terry Mick  
Holder Construction Company  
3333 Riverwood Parkway, Suite 400  
Atlanta, GA 30339

Dear Mr. Mick:

This letter is written regarding the storm water inspection I conducted at Project Buckeye Data Center, located in Delaware County, on December 13, 2006. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment Controls:**

1. I noted at the extreme southwest corner of the site a small temporary sediment basin which drains the southwest corner. It appears this basin does not meet the required sediment storage of 67 cubic yards per acre of drainage. The point of overflow and the impounded water noted concurrent with my inspection on December 13, 2006 clearly demonstrated minimal sediment storage volume. This basin must be enlarged to meet the required volume within seven days of receipt of this letter.
2. I have noted a large pit in association with the northern drainage area. This pit is directly below a large storm sewer. Again, I am concerned that the required sediment storage for this area has not been met. I have received a follow-up letter which indicates that sediment storage for this northern area has been obtained. However, based on the current site observations, I am concerned that addition volume will be required.

**Erosion Controls:**

I noted that significant areas had been protected with a mulch cover. Please continue to implement mulch or an approvable alternative to ensure effective erosion control in preparation for the upcoming winter months. In addition measures must be taken to ensure that the mulch is secured in place. In the event that mulch is washed away concurrent with upcoming precipitation events, reapplication will be required.

Bob Taft, Governor  
Bruce Johnson, Lieutenant Governor  
Joseph P. Koncelik, Director



Printed on Recycled Paper

Ohio EPA is an Equal Opportunity Employer

Terry Mick  
Holder Construction Company  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office