



State of Ohio Environmental Protection Agency

STREET ADDRESS

Lazarus Government Center  
122 S. Front Street  
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS

P.O. Box 1049  
Columbus, Ohio 43216-1049

December 18, 2006

Bill Dorman  
Village of New Albany  
6208 Dublin-Granville Road  
New Albany, Ohio 43054

Dear Mr. Dorman:

This letter is in reference to my inspection of two construction sites located within the Village of New Albany. On December 13, 2006, I evaluated the construction activities associated with the New Albany Police Station and the Leisure Trail constructed near Maplewood Cemetery. These inspections were prompted via complaints to our Central District Office.

Based on my site observations and the conditions of the General Storm Water Permit the following items must be addressed. Please forward a copy of this inspection report to the corresponding developers to ensure prompt and effective corrective measures.

**New Albany Police Station:**

1. Recent concrete work around the perimeter of the New Albany Police Station has resulted in the removal of portions of the perimeter controls. These perimeter controls must be reestablished.
2. Measures must be taken to minimize off-site vehicle tracking given that I noted significant tracking of mud onto public roads.
3. Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.
4. Given the time of year earth moving activities extended beyond the effective growing season, alternative erosion protection will be required to fully stabilize the area for winter (i.e., erosion control matting or crimp mulching).

Bob Taft, Governor  
Bruce Johnson, Lieutenant Governor  
Joseph P. Koncelik, Director

Bill Dorman  
Village of New Albany  
Page -2-

**Maplewood Cemetery Leisure Trails:**

Completion of this site was noted. Please ensure that all erosion controls are implemented at this time.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office