



State of Ohio Environmental Protection Agency

STREET ADDRESS

Lazarus Government Center
122 S. Front Street
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS

P.O. Box 1049
Columbus, Ohio 43216-1049

December 12, 2006

Benson NG
Luxuriiv Bldg Supply Inc.
999 Bethel Road – Rear Units A B & C
Columbus, OH 43214

Dear Mr. NG:

This letter is written as a follow up to a storm water inspection Pamela Olson, with our office, conducted at Luxuriiv Bldg Supply, on December 5, 2006. This construction site located in Delaware County is currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the conditions set forth in the General Permit, the following items will require attention:

Sediment and Erosion Controls:

Given the time of year alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implement for this site to ensure effective erosion control for the upcoming winter months.

Post Construction:

The General Permit mandates specific water quality treatment for storm water following the completion of construction (see attachment). Please be able to demonstrate that your post construction requirements per the General Permit will be met. Please submit to my attention, the water quality calculations demonstrating compliance. This information can be sent to my attention via a response letter, or to my email at: harry.kallipolitis@epa.state.oh.us.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. A follow up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, CDO/DSW


HK/nsm Luxuriiv Bldg Supply Dec. 6, 2006

Bob Taft, Governor
Bruce Johnson, Lieutenant Governor
Joseph P. Koncelik, Director



Printed on Recycled Paper

Ohio EPA is an Equal Opportunity Employer





State of Ohio Environmental Protection Agency

STREET ADDRESS

Lazarus Government Center
122 S. Front Street
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS

P.O. Box 1049
Columbus, Ohio 43216-1049

December 12, 2006

John Jones
14471 Graham Road
Pataskala, OH 43062

Dear Mr. Jones:

This letter is written as a follow up to my storm water inspection conducted at your site on the southwest corner of US Route 40 and Mink Road in Licking County, on November 29, 2006. This construction site is located in Etna Township adjacent to Sycamore Creek. Based on my site inspection the following items should be addressed to avoid violation of the Ohio Revised Code, Chapter 6111.04:

Sediment and Erosion Controls:

1. During my inspection it was noted that the perimeter controls along Sycamore Creek require maintenance.
2. I noted the site remains barren. Given the time of year, alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implement for this site to ensure effective erosion control for the upcoming winter months.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844.

Sincerely,


Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, CDO/DSW

HK/nsm John Jones Dec. 6, 2006

Bob Taft, Governor
Bruce Johnson, Lieutenant Governor
Joseph P. Koncelik, Director



Ashton Crossing
Blacklick Creek Watershed
Fairfield County
12-04-2006
Photo by: Pam Olson




Figure 1 Large stockpile east of pond

