

UNITED STATES POSTAL SERVICE



First-Class Mail
Postage & Fees Paid
USPS
Permit No. G-10

• Sender: Please print your name, address, and ZIP+4 in this box •

OHIO EPA/CDO/DSW
HARRY KALLIPOLITIS
P.O. BOX 1049
COLUMBUS, OH 43216-1049

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

HazeltonTown Center
 LovelandDevelopment
 Incorporated
 924 1/2 B State Route28
 Milford, OH 45150



COMPLETE THIS SECTION ON DELIVERY

A. Signature

X *G. Jacobs*

- Agent
- Addressee

B. Received by (Printed Name)

GREG JACOBS

C. Date of Delivery

12/23/06

D. Is delivery address different from item 1? Yes
 (If YES, enter delivery address below: No

RECEIVED

DEC 28 2006

3. Service Type

- Certified Mail
- Registered Mail
- Insured Mail
- Express Mail
- Return Receipt for Merchandise
- C.D.M.

4. Restricted Delivery? (Extra Fee) Yes

2. Article Number
 (Transfer from service label)

7006 0810 0000 4251 0002

OHIO EPA/CDO



State of Ohio Environmental Protection Agency

STREET ADDRESS

Central District Office

MAILING ADDRESS

Lazarus Government Center
122 S. Front Street
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, Ohio 43216-1049

CERTIFIED MAIL #7006 0810 0000 4251 0002

December 12, 2006

HazeltonTown Center
LovelandDevelopment Incorporated
924 1/2 B State Route28
Milford, OH 45150

Dear Permittee:

This letter is written regarding the storm water inspection I conducted at Hazelton Town Center located in Licking County on State Route 310 on November 29, 2006. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

1. As I have indicated per previous inspections, a sediment basin on the east side of State Route 310 must be installed. It is apparent that the storm sewer system is completed which will require the installation of the sediment basin.
2. During the inspection, I noted barren areas. Given the time of year alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implement for this site to ensure effective erosion control for the upcoming winter months.

Post Construction:

The General Permit mandates specific water quality treatment for storm water following the completion of construction (see attachment). Please be able to demonstrate that your post construction requirements per the General Permit will be met. Please submit to my attention, the water quality calculations demonstrating compliance. This information can be sent to my attention via a response letter, or to my email at: harry.kallipolitis@epa.state.oh.us.

Bob Taft, Governor
Bruce Johnson, Lieutenant Governor
Joseph P. Koncelik, Director

