



State of Ohio Environmental Protection Agency

STREET ADDRESS

Lazarus Government Center
122 S. Front Street
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS

P.O. Box 1049
Columbus, Ohio 43216-1049

December 11, 2006

Dennis King
River Run of Powell LLC
10534 Church Hill Drive
Powell, Ohio 43065

Dear Mr. King:

This letter is written as a follow up to a storm water inspection Pamela Olson of Ohio EPA conducted at River Run Subdivision, on December 5, 2006. This construction site located in Delaware County is currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the conditions set forth in the General Permit, the following items were noted:

Sediment and Erosion Controls:

1. The mulch cover was still properly functioning, however, please be sure to monitor the site in the event reapplication becomes necessary.
2. This general permit states that all sediment controls and erosion must be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, CDO/DSW

HK/nsm River Run Dec. 6, 2006

Bob Taft, Governor
Bruce Johnson, Lieutenant Governor
Joseph P. Koncelik, Director



Printed on Recycled Paper

Ohio EPA is an Equal Opportunity Employer

