



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 14, 2007

**VINTON COUNTY
GENERAL FILE
(HUNTLEY TRUCKING CO.)
DHWM/SEDO
OHD054025325**

Ms. Jettie Huntley
Huntley Trucking Co.
23525 Pumpkin Ridge Road
New Plymouth, Ohio 45654

Dear Ms. Huntley:

Thank you for your May 3, 2007 response to Ohio EPA's April 10, 2007 Notice of Violation letter. The documentation you submitted included photographic documentation demonstrating that used oil containers have been properly labeled, and the oil absorbent pile has been properly disposed of. Also included was information on your intended management of spent fluorescent lamps.

My review of this documentation reveals that Huntley Trucking has abated all violations of Ohio's hazardous waste laws and regulations discovered during the April 3, 2007 inspection.

Other Compliance Issues:

- (a) Your facility has two above-ground diesel storage tanks exceeding the capacity of at least 1,320 gallons. Therefore, the federal Spill Prevention, Control and Countermeasure (SPCC) requirements (40 CFR 112) apply to your facility. Please see the attached fact sheet and the USEPA SPCC web page at <http://www.epa.gov/oilspill/spcc.htm> for more information regarding the SPCC requirements. For additional SPCC compliance assistance, please contact Dennis Deavers in the Southeast District Office Emergency Response Section.

If you have any questions regarding waste management or pollution prevention activities, please call me at (740) 380-5262.

Sincerely,

John Rochotte
District Representative
Division of Hazardous Waste Management

JR/mlm

NOTICE:

Ohio EPA's failure to list specific deficiencies or violations in this letter does not relieve your company from having to comply with all applicable regulations.