



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

November 2, 2011

Bob Sidwell
CD Gaming Ventures Inc.
825 Berkshire Boulevard
Wyomissing, PA 19610

**Re: Hollywood Casino, Franklin County
Construction Storm Water Permit Number: 4GC03516*AG**

Dear Mr. Sidwell:

This letter is written regarding a storm water inspection that I conducted at the Hollywood Casino located at 200 Georgesville Road Columbus, Ohio on October 26, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

There was a small section of silt fence that needed to be maintained near the well drilling operation. Also, it is requested that the straw waddles or other additional erosion controls be installed in this area to prevent sediment from the well drilling operation from discharging off-site. Please see attached pictures.

Be aware the General Permit states that all barren areas including stockpiles and sediment pond banks which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. Given the time of year alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implement for this site to ensure effective erosion control for the upcoming winter months. You stated that you anticipate the barren areas to be stabilized within ten days.

Please insure mud is not tracked on to Broad Street from the construction site. Implement best management practices and install erosion controls as needed.

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

Bob Sidwell
CD Gaming Ventures Inc.
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at 614-728-3851 or email at greg.sanders@epa.ohio.gov.

Sincerely,



Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO
Ron Beuttenmuller, Smoot Construction

ec: Greg Sanders, DSW/CDO

GS/nsm Hollywood Casino, October 26, 2011

Hollywood Casino
Stabilize around sediment pond
Scioto River Watershed
October 26, 2011
Photo by Greg Sammons



Hollywood Casino
Maintain erosion controls
Install additional controls
Scioto River Watershed
October 19, 2011
Photo by Greg Sammons

