





Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 18, 2011

Tim Richards
TH Midwest Inc.
2600 Corporate Exchange Drive
Suite 170
Columbus, OH 43231

**Re: Storm Water Inspection at Turkey Hill Minit Market #707 / Delaware County
Permit Number: 4GCO00053*AG**

Dear Mr. Richards:

This letter is written in follow up to a construction storm water inspection I conducted at Turkey Hill Minit Market #707 located at 2740 Stratford Road in Delaware, Ohio on September 22, 2011. **This letter represents a Notice of Violation for failure to maintain sediment and erosion controls in accordance with General Permit.** The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

- The permittee has failed to maintain the perimeter silt fence associated with this site. I noted several areas where the silt fence has failed to be maintained. Corrective measures are expected to maintain all silt fence in accordance with the permit.
- Inlet protections have been provided for the drop catch basins. However, the weep holes at the side of the catch basin inlets are open, providing a direct bypass of the intended sediment controls. This provides a direct conduit of sediment laden water directly into the main stem of the Olentangy River. Corrective measures are expected to provide appropriate inlet protections to provide ponding of water to meet the intent of the general permit.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Turkey Hill Minit #707

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

