



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 18, 2011

Scott Earhart
Earhart Petroleum Inc.
P.O. Box 39
Troy, OH 45373

Re: **Storm Water Inspection at Earhart Petroleum Inc. / Franklin County**
Permit Number: 4GR00346*DG

Dear Mr. Earhart:

This letter is written in follow up to an industrial storm water inspection I conducted at Earhart Petroleum Inc. located in Columbus, Ohio on September 27, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Industrial Activities. During the inspection, the following was noted:

Storm Water Pollution Prevention Plan (SWPPP):

- A Storm Water Pollution Prevention Plan (SWPPP) must be developed specific for this site. The SWPPP must address all materials and processes exposed to Storm water. A site map must be developed which clearly delineates all drainage patterns and storm water outfalls associated with this site. In addition, the site map must include the location of all Best Management Practices (BMPs) implemented to minimize the threat of storm water contamination. ***Please submit to my attention the most recent SWPPP for review. An electronic copy to my email at harry.kallipolitis@epa.ohio.gov is preferred.***

Tank Farm:

- A secondary containment associated with the current tank farm does not meet the expectations of the general storm water permit. Corrective measures are expected to replace the secondary containment structure and provide a contained offloading pad.

Dewatering Protocol:

- A dewatering protocol must be established authorizing the release of accumulated storm water within all areas of secondary containment. It is my understanding that all water accumulated in those areas of secondary containment is hauled off for disposal. Please provide me any documentation that supports this claim. In addition, please provide a final area of disposal for all accumulated storm water.

Staging Area:

- It is also recommended that secondary containment is also provided for all staging areas associated with this facility.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO