



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 11, 2011

Kim Harper
BSS Waste
P.O. Box 879
Logan, OH 43138

Re: BSS Waste Facility / Fairfield County

Dear Mr. Harper:

This letter is written regarding the storm water inspection I conducted of the construction activities of the BSS Waste Facility, located near the intersection of Ruble Park Drive and Whitey Road, on September 30, 2011. I understand this site is currently covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the conditions set forth in the General Permit, the following items must be addressed:

Sediment and Erosion Controls:

- A small area around the building was still barren. Please be aware the General Permit states that erosion protection (seed and straw) must be implemented for all areas of final grade within seven (7) days. The site appeared to be at final grade and there was no active construction activity. Please see attached pictures.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,


Gregory L. Sanders
Environmental Specialist
Stormwater Section
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, DSW/CDO

ec: Gregory L. Sanders, DSW/CDO

GLS/nsm BSS Waste Facility, September 30, 2011



BSS Waste Facility
Stabilize barren areas
Hocking River Watershed
September 30, 2011

