



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

October 7, 2011

Pastor Virgil Phillips  
House of Blessings Worship Center  
3633 Big Run South Road  
Grove City, OH 43123

**Re: House of Blessings Worship Center / Franklin County**

Dear Pastor Phillips:

This letter is written in follow up to a construction storm water inspection that I conducted at the House of Blessings Worship Center located at 3633 Big Run South Road on September 28, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following was noted:

**Sediment and Erosion Controls:**

- A small area around the building was barren. Your contractor stated that earthwork would commence in several weeks. Please be aware the General Permit states that all barren areas including stockpiles which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. The site appeared to be near final grade and there was no active construction activity.
- Please install and maintain silt fence on the down slope of the construction site prior to starting the earthwork.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

ec: Gregory L. Sanders, DSW/CDO

GS/nsm: House of Blessings Worship Center, September 28, 2011









