



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 6, 2011

Jeremiah Johnson
The Beaver Excavating Company
2000 Beaver Place Avenue Southwest
Canton, OH 44706

**Re: Storm Water Inspection at City of Columbus Upland Reservoir
Union County
Permit #4GC03524*AG**

Dear Mr. Johnson:

This letter is written in follow-up to a construction storm water inspection I conducted at Columbus Upland Reservoir located at 10065 Taway Road, Radnor, Ohio on September 15, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls

- During the inspection, I observed the discharges from Sediment Pond 1, 2, and 4. Discharges on this date appeared relatively free from suspended solids. However, I remain concerned that the areas designated to receive dewatering activities are designed for storm water treatment. This is contrary to the plan. All storm water drainage should be routed to the pond intended for sediment control. This specifically applies to the drainage areas associated with the impoundment off of Taway Road and Mooney Road. At this time, I am formally requesting an on-site inspection to determine current storm water flows.
- Please submit to my attention a temporary revegetation plan to address barren areas in preparation for the upcoming winter months. Please be able to identify all areas that will require temporary seeding and mulching for the 1100 acre site.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Upland Reservoir 9-15-11

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

