



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 6, 2011

Ron Strussion
Reynoldsburg City School District
7244 East Main Street
Reynoldsburg, OH 43068

**Re: Construction Storm Water Inspection at Summit High School Complex /
Licking County
Permit Number 4GC03083*AG**

Dear Mr. Strussion:

This letter is written in follow-up to a construction storm water inspection I conducted at 8579 & 8591 Summit Road in Reynoldsburg, Ohio on September 20, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The majority of the disturbed areas west of the small tributary have been stabilized sufficiently to control erosion.
- Newly disturbed areas west of the small tributary remain uncontrolled. I noted minimal perimeter controls along the stream which fail to meet the intent of the permit. This site was initially controlled via the installation of several sediment impoundments. Additional controls are required at this time to abate the current violation of your General Storm Water Permit. Please install all controls in accordance with the approved Storm Water Pollution Prevention Plan within seven days of receipt of this letter.

Winter Rule:

- All barren and idle areas must be protected in preparation for the upcoming winter months. Please note if earth disturbing activities extend beyond a successful vegetative growing season, alternate controls are expected. This would include but not limited to, a crimped mulched cover.

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

Ron Strussion
Reynoldsburg City School District
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (***email preferred***) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Summit School complex