



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

October 6, 2011

Judyth Dobbert-Meloy  
Whitehall City Schools  
625 South Yearling Road  
Whitehall, OH 43213

**Re: Construction Storm Water Inspection at Rosemore Middle School  
Franklin County  
Permit #4GC03298\*AG**

Dear Ms. Dobbert-Meloy:

This letter is written regarding a construction storm water inspection I conducted at Rosemore Middle School, located at 4735 Kae Avenue, Whitehall, Ohio, 43213 on September 14, 2011. I understand this facility is currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment and Erosion Controls**

- A centralized sediment basin for this site has been corrected. The temporary riser has been installed as requested, to ensure appropriate sediment control during the construction phase of this project.
- **Post-construction:** Please note the dry basin as depicted in the SWPPP will not meet the minimum requirements of the general permit. A micro-pool and fore bay sized at 10% of the water quality volume each must be incorporated into this design.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Rosemore Middle School 9-14-11

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
www.epa.ohio.gov

