Ohio | Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 6, 2011

Edward J. Seeberger
Pactiv Corporation
2120 Westbelt Drive
Columbus, OH 43228

Re: Industrial Storm Water Inspection at Pactiv Corporation
Franklin County
Permit #4GR00070*DG

Dear Mr. Seeberger:

This letter is written in follow-up to a preliminary industrial storm water inspection I conducted at Pactiv Corporation, located at 1999 Dividend Drive, Columbus, Ohio on September 14, 2011. I understand this facility is currently covered under our industrial storm water permit. The purpose of the inspection was to evaluate compliance with the general permit associated with the materials and processes exposed to storm water at this facility. Based on my preliminary site observation and the conditions of the general permit, the following observations were noted:

- **Storm water Pollution Prevention Plan (SWPPP):** a SWPPP must be developed specifically for this facility. The SWPPP must identify all materials and processes which have the potential for contaminating storm water runoff. A site map must be developed depicting all drainage patterns, location of all exposed materials and processes, and the associated Best Management Practices (BMP) utilized to minimize storm water contamination. The SWPPP must be on-site available for review. Please refer to the following link to reference for developing a SWPPP:
  www.epa.gov/npdes/pubs/industrial_swppp_guide.pdf

- I noted a large collection system on the roof associated with this facility. Please ensure a roof management plan is in incorporated into your SWPPP which routinely inspects the roof for materials which may contaminate storm water. In the event these materials are exposed, prompt and effective cleanup is expected. A log of the roof inspection should be maintained in the SWPPP.

- **Trash compactor:** A trash compactor was noted on site. Please routinely ensure the compactor is watertight and not leaking or expelling fluids.

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

If you have any questions regarding this preliminary inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Pactiv Corporation dividend Drive 9-14-11