



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

October 5, 2011

Eric Leu  
Columbus Southern Power Co. DBA AEP  
1 Riverside Plaza  
Columbus, OH 43215

**Re: Storm Water Inspection at Roberts – OSU 138 KV Line  
Franklin County  
Permit # 4GC03401\*AG**

Dear Mr. Leu:

This letter is written in follow-up to a construction storm water inspection I conducted at Roberts – OSU 138 KV Line located at Roberts Road Station to OSU Station, Upper Arlington and Columbus, Ohio, on September 20, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

#### **Sediment and Erosion Controls**


- The silt fence on the eastern portion of the site must be maintained at all times until upland vegetation is established sufficient to control erosion.
- Continued measures must be implemented to minimize offsite vehicle tracking from this site.
- According to the contractor, the slopes leading down to Cannon Drive will be seeded and mulched by September 23, 2011.

The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Eric Leu  
Columbus Southern Power Co. DBA AEP  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO