



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 5, 2011

Edwin Hanson
Columbus Gaming Ventures Inc.
825 Berkshire Boulevard
Wyomissing, PA 19610

**Re: Storm Water Inspection at Jaeger Commerce Park – Redevelopment Site
Franklin County
Permit #4GC03201*AG**

Dear Mr. Hanson:

This letter is written in follow up to a construction storm water inspection I conducted at Jaeger Commerce Park – Redevelopment Site located at 500 – 560 Nationwide Boulevard, Columbus, Ohio on September 20, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls

- As requested, I evaluated the vegetative stand associated with this site. Vegetation is NOT established for sufficient control of erosion measured by a minimum vegetative density of 70%. In accordance with the general permit, the sediment ponds must remain until such a time as vegetation is established sufficiently to control erosion. I will continue to closely monitor the site to advise you regarding the vegetative stand associated with this site.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Jaeger Commerce Park Redevelopment site 9-20-11

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

