



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

October 3, 2011

D Steven Allen
London City School District
60 S Walnut Street
London, OH 43140

Re: London Middle School / Madison County

Dear Mr. Allen:

This letter is written in follow-up to a construction storm water inspection that I conducted at the London Middle School located at between 336 Elm Street and 380 Elm Street, in London, Ohio, on September 27, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Please be aware the General Permit mandates specific permanent and temporary stabilization requirements. All disturbed areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. All areas of final grade must be protected within seven days. It appeared that except for the dirt stockpiles, that most barren areas were at final grade.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851 or email at greg.sanders@epa.state.oh.us.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

cc: Gregory L. Sanders, DSW/CDO

GS/nsm London Middle School, September 27, 2011

