



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

September 30, 2011

Jerry Brems
20 South Second Street
Newark, OH 43055

**Re: Storm Water Inspection at Etna Parkway/ Licking County
Permit Number: 4GC03129*AG**

Dear Mr. Brems:

This letter is written in follow up to a construction storm water inspection I conducted at Etna Parkway located in Pataskala, Ohio on September 9, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following was noted:

Sediment and Erosion Controls:

- It appears that the majority of the site has been seeded and mulched in accordance with my previous inspection reports.
- The large stockpile located on Refugee Road has also been seeded and mulched per my request.
- Please continue to monitor all vegetation to ensure a successful cover measured by a minimum vegetative density of 70 percent.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Etna Parkway 9-9-11

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

