



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

September 30, 2011

Han Nguyen
Keystone Construction, Incorporated
2415 South High Street
Columbus, OH 43207

Re: Suburban Village / Pickaway County

Dear Mr. Nguyen:

This letter is written in follow-up to a construction storm water inspection that I conducted at the Suburban Village located at the corner of Jefferson Street and Station Street on September 21, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Sediment and Erosion Controls:

There did not appear to be any construction activity at the site. The site was stabilized and no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

ec: Greg Sanders, DSW/CDO

GS/nsm Suburban Village, September 21, 2011

