



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

September 26, 2011

Don Wick  
Rockford Homes  
999 Polaris Parkway  
Columbus, OH 43240

**Re: Meadow Grove South, Sec. 8 / Franklin County**

Dear Mr. Wick:

This letter is written regarding the storm water inspection that I conducted near the intersection of Blue Star Drive and Deergrass Court, in Grove City, Franklin County, on September 16, 2011. The agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following was observed or discussed at the site:

**Sediment and Erosion Controls:**

There did not appear to be any construction activity at the site. The site was stabilized and no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

c: Jeff Bohne, DSW/CDO

ec: Greg Sanders, DSW/CDO

GS/nsm Meadow Grove Estates North, September 16, 2011

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
www.epa.ohio.gov

