



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

September 26, 2011

Mark Bush  
Bremen DG LLC  
361 Summit Boulevard  
Suite 110  
Birmingham, AL 35243

**Re: Construction Storm Water Inspection at Bremen Dollar General  
Fairfield County  
Permit Number: 4GC03582 \*AG**

Dear Mr. Bush:

This letter is written regarding a storm water inspection that I conducted at Dollar General located on State Route 664 just south of State Route 37 Bremen, Ohio on September 19, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. It appeared during the inspection that construction activity has been completed for this site and all disturbed areas had been permanently stabilized. Please address the following:

**Post Construction Requirements:**

The General Permit mandates specific water quality treatment for storm water following the completion of construction (see attachment). Please be able to demonstrate your post construction requirements per the General Permit will be met. Please submit to my attention the water quality calculations demonstrating compliance. This information can be sent to my attention via a response letter, or to my email at [greg.sanders@epa.ohio.gov](mailto:greg.sanders@epa.ohio.gov).

If you have not already done so, a Notice of Termination will be required providing that the post construction requirements have been met. Instructions and forms can be found at <http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851 or email at [greg.sanders@epa.ohio.gov](mailto:greg.sanders@epa.ohio.gov).

Sincerely,

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

ec: Greg Sanders, DSW/CDO

GS/nsm Bremen dollar General, September 19, 2011

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)

