



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

September 22, 2011

David Johnson  
ODOT District 5  
9600 Jacksontown Road Southeast  
PO Box 306  
Jacksontown, OH 43030

**Re: Storm Water Inspection at State Route 79 Licking County  
Permit # 4GC03450\*AG**

Dear Mr. Johnson,

This letter is written regarding the storm water inspection I conducted at State Route 79 on August 30, 2011. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

**Sediment and Erosion Controls:**

- I noted the installation of sediment controls and inlet protection as a primary means of minimizing offsite sedimentation. Please ensure all controls are maintained to continue compliance with the general permit. Elevation corrections of all inlet protections should be considered to minimize potential flooding of State Route 79.
- During the investigation, I spoke with Jim Miller who currently resides at 689 Radian Drive in Heath, Ohio. At the time of the inspection, I evaluated his drainage concerns associated with the new road installation directly adjacent to his house. At this time, I am formally requesting an on-site investigation to determine any potential means to alleviate his drainage concerns. Please understand that post-construction stormwater management controls are also expected within this area.

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)

David Johnson  
ODOT District 5  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, CDO/DSW

HK/nsm State Route 79