




Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

FILE COPY



NOTICE OF VIOLATION – ACTION REQUIRED

CERTIFIED MAIL # 91 7108 2133 3932 1838 4288

December 29, 2011

Larry D. Cordial
8927 Columbus Road
Mount Vernon, OH 43050

Knox County
Colonial Terrace MHP
COMMUNITY PWS
PWS ID: OH4201512

SUBJECT – MONTHLY REPORTING VIOLATIONS

We have made several efforts to provide instruction on reporting information on the monthly operating reports (MORs). In reviewing the September, October and November 2011 MORs, it is evident that there continues to be a misunderstanding about the information required to be included.

We are requesting a meeting at the Ohio EPA Lazarus Government Building, 50 West Town Street in early January. Within 14 days of the date of this letter, please contact me to set a date and time.

Colonial Terrace MHP is in violation of the following requirements for September, October and November 2011:

1. Failure to maintain at least a 0.2 mg/L free or 1.0 mg/L combined chlorine residual at Treatment facility #1 (each day in both October and November).
2. Failure to report valid Total chlorine residual values (October and November).
3. Failure to identify the month for which the report was prepared (September).
4. Failure to submit the reports to our office by the 10th of each month following the month for which it was prepared (October).

I can be reached at (614) 728-3864 or at carolyn.o'neal@epa.state.oh.us.

Sincerely,

Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

c: Knox County Health Department
Tiara Bryant, DDAGW/CDO
MC/MR-STATE

CO/cr 4201512(M)SepOctNov2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov