



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Seneca County
Weber Hall
TNC Water System
PWSID: OH7447712
STUID: 7458182

December 14, 2011

CERTIFIED MAIL

Kelly and Judy Weber
Weber Hall
927 N Main Street
Fostoria, OH 44830

Subject: Notice of Violation for Failure to Respond to a Significant Deficiency

This letter is notification that Weber Hall has not complied with requirements issued during this Agency's last survey performed on May 11, 2011, in violation of rule 3745-81-60 of the Ohio Administrative Code. Weber Hall was notified in correspondence dated May 24, 2011, to respond in writing no later than 30 days, with time frames for:


1. Install an appropriately designed well cap that prevents the entrance of water, dirt, animals, insects or other foreign matter. The cap shall have a threaded and sealed conduit connection. The cap shall also have an integrated vent that is self-draining, screened, and pointed downward. [OAC Rule 3745-9-05(P)(T)]
2. Collect total coliform samples quarterly. Total coliform samples were not collected for the fourth quarter of 2010 and the first quarter of 2011. [OAC Rule 3745-81-21(A)(2)(a)]
3. Display all required public notices. A Tier 3 public notice shall be posted for all violations of monitoring requirements. In Notice of Violation letters dated January, 28, 2011, and May 12, 2011, Ohio EPA sent Weber Hall copies of the required public notices and verification forms. Display each of these public notices, complete the verification forms, and return the verification forms to Ohio EPA. Please contact me if additional copies of public notice or verification forms are needed. [OAC Rule 3745-81-32(D)]

Kelly and Judy Weber
December 14, 2011
Page 2

The water system must **respond in writing within 15 days from the date of this letter** with the required information. Failure to comply may result in further enforcement action. Your response must contain either time frames for meeting the above requirements, or the completed Public Water System Deactivation Request Form sent to Weber Hall in correspondence dated September 1, 2011.

If you have any questions, please contact me at 419-373-3107 or elizabeth.ames@epa.state.oh.us.

Sincerely,



Elizabeth Ames
Environmental Specialist 2
Division of Drinking and Ground Waters

/lr

pc: Seneca County Health Department
Central Office, DDAGW
Certified Mail Receipt Number 7009 1410 0001 1834 1859